

## ANALYTICAL REPORT

Eurofins Environment Testing Philadelphia, LLC  
213 Witmer Road  
Horsham, PA 19044-0962  
Tel: (215)355-3900

Laboratory Job ID: 630-30668-1


Client Project/Site: Harmony Township Elementary -  
Lead/Copper

Sampling Event: Semi-Annual PB/CU

For:

Harmony Township Board of Education  
2551 BELVIDERE ROAD  
PHILLIPSBURG, New Jersey 08865

Attn: Tim McKeever



Authorized for release by:  
4/18/2022 1:27:15 PM

Erin Dougherty, Project Administrator  
(215)355-3900

[Erin.Dougherty@et.eurofinsus.com](mailto:Erin.Dougherty@et.eurofinsus.com)

### LINKS

Review your project  
results through

TotalAccess

Have a Question?




Visit us at:

[www.eurofinsus.com/Env](http://www.eurofinsus.com/Env)

*The test results in this report meet all 2003 NELAC, 2009 TNI, and 2016 TNI requirements for accredited parameters, exceptions are noted in this report. This report may not be reproduced except in full, and with written approval from the laboratory. For questions please contact the Project Manager at the e-mail address or telephone number listed on this page.*

*This report has been electronically signed and authorized by the signatory. Electronic signature is intended to be the legally binding equivalent of a traditionally handwritten signature.*

*Results relate only to the items tested and the sample(s) as received by the laboratory.*



Analytical test results meet all requirements of the associated regulatory program (e.g., NELAC (TNI), DoD, and ISO 17025) unless otherwise noted under the individual analysis. Data qualifiers are applied to note exceptions. Noncompliant quality control (QC) is further explained in narrative comments. QC data that exceed the upper limits and are associated with non-detect samples are qualified but no further narration is needed since the bias is high and does not change a non-detect result. Regulated compliance samples (e.g. SDWA, NPDES) must comply with the associated agency requirements/permits.

#### Coliform MCLs

- Based on the EPA primary drinking water standard MCL for total coliforms, a water supply is considered bacteriologically "SAFE" if no coliform bacteria are detected. To be considered "SAFE" your report should indicate "<1 cfu/100mL" or "NEG" for the coliform test. If you report indicates a positive result "POS" or a value greater than or equal to one, then your supply is "UNSAFE FOR DRINKING" contact your local health department.

#### Warranties, Terms, and Conditions

- Analyses for Field Parameters are performed by EQC field staff. Locations and certifications are identified on the Chain of Custody as follows:

ERF = field staff performs tests under NJ State certification #02015

VL = field staff performs tests under NJ State certification #06005

WG = field staff performs tests under NJ State certification #PA001

H = field staff performs tests under NJ NELAP certification #PA093, PA NELAP certification # 46-

05499

- Test results meet all TNI or other applicable regulatory agency requirements, including holding times and preservation, unless otherwise indicated.

- The report shall not be reproduced, except in full, without the written consent of the laboratory

- All samples are collected as "grab" samples unless otherwise identified.

- Reported results related only to the samples as tested. EQC is not responsible for sample integrity unless sampling has been performed by a member of our staff.

- EQC is not responsible for sampling and/or testing omissions. Note that regulatory authorities may assess substantial fines for testing omissions. Please track your sample collection schedules and results on a regular basis (e.g. weekly, monthly, or quarterly) to ensure compliance.

- Eurofins' online data portal "TotalAccess" will provide you with real-time access to collection dates and testing results. Please contact Client Services for further information.

- The following personnel or their deputies have approved the results of the tests performed by EQC: Nicki Smith (Environmental Chemistry) and Jacqueline Gartner (Water Microbiology).

---

Erin Dougherty  
Project Administrator  
4/18/2022 1:27:15 PM

## Case Narrative

Client: Harmony Township Board of Education  
Project/Site: Harmony Township Elementary - Lead/Copper

Job ID: 630-30668-1

---

**Job ID: 630-30668-1**

---

**Laboratory: Eurofins Environment Testing Philadelphia, LLC**

---

**Narrative**

**Job Narrative**  
**630-30668-1**

**Receipt**

The samples were received on 4/7/2022 2:27 PM. Unless otherwise noted below, the samples arrived in good condition, and, where required, properly preserved and on ice. The temperature of the cooler at receipt time was 12.9°C

**Metals**

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

## Sample Summary

Client: Harmony Township Board of Education  
Project/Site: Harmony Township Elementary - Lead/Copper

Job ID: 630-30668-1

Lab Sample ID	Client Sample ID	Matrix	Collected	Received	PWSID Number
630-30668-1	PBCU1 KITCHEN SINK RIGHT	Drinking Water	04/07/22 06:39	04/07/22 14:27	NJ2110300
630-30668-2	PBCU2 2ND FL FTN CORRIDOR	Drinking Water	04/07/22 06:45	04/07/22 14:27	NJ2110300
630-30668-3	PBCU3 RIGHT FTN BY STORAGE	Drinking Water	04/07/22 06:36	04/07/22 14:27	NJ2110300
630-30668-4	PBCU4 RIGHT FTN BY BOYS RM	Drinking Water	04/07/22 06:25	04/07/22 14:27	NJ2110300
630-30668-5	PBCU5 KITCHEN SINK LEFT	Drinking Water	04/07/22 06:38	04/07/22 14:27	NJ2110300
630-30668-6	PBCU6 NURSES HAND SINK	Drinking Water	04/07/22 06:30	04/07/22 14:27	NJ2110300
630-30668-7	PBCU7 FTN BY ROOM 105	Drinking Water	04/07/22 06:33	04/07/22 14:27	NJ2110300
630-30668-8	PBCU8 TEACHERS LOUNGE	Drinking Water	04/07/22 06:27	04/07/22 14:27	NJ2110300
630-30668-9	PBCU9 LEFT FTN BY STORAGE	Drinking Water	04/07/22 06:37	04/07/22 14:27	NJ2110300
630-30668-10	PBCU10 KINDERGARTEN HS	Drinking Water	04/07/22 06:31	04/07/22 14:27	NJ2110300

# Client Sample Results

Client: Harmony Township Board of Education  
Project/Site: Harmony Township Elementary - Lead/Copper

Job ID: 630-30668-1

## Client Sample ID: PBCU1 KITCHEN SINK RIGHT

Lab Sample ID: 630-30668-1

Date Collected: 04/07/22 06:39

Matrix: Drinking Water

Date Received: 04/07/22 14:27

PWSID Number: NJ2110300

### Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Copper	0.15		0.010	0.0023	mg/L		04/18/22 12:24	1	S4PD
Lead	0.0022		0.0010	0.00069	mg/L		04/18/22 12:24	1	S4PD

## Client Sample ID: PBCU2 2ND FL FTN CORRIDOR

Lab Sample ID: 630-30668-2

Date Collected: 04/07/22 06:45

Matrix: Drinking Water

Date Received: 04/07/22 14:27

PWSID Number: NJ2110300

### Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Copper	0.071		0.010	0.0023	mg/L		04/18/22 13:12	1	S4PD
Lead	ND		0.0010	0.00069	mg/L		04/18/22 13:12	1	S4PD

## Client Sample ID: PBCU3 RIGHT FTN BY STORAGE

Lab Sample ID: 630-30668-3

Date Collected: 04/07/22 06:36

Matrix: Drinking Water

Date Received: 04/07/22 14:27

PWSID Number: NJ2110300

### Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Copper	0.045		0.010	0.0023	mg/L		04/18/22 12:51	1	S4PD
Lead	ND		0.0010	0.00069	mg/L		04/18/22 12:51	1	S4PD

## Client Sample ID: PBCU4 RIGHT FTN BY BOYS RM

Lab Sample ID: 630-30668-4

Date Collected: 04/07/22 06:25

Matrix: Drinking Water

Date Received: 04/07/22 14:27

PWSID Number: NJ2110300

### Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Copper	0.046		0.010	0.0023	mg/L		04/18/22 13:15	1	S4PD
Lead	ND		0.0010	0.00069	mg/L		04/18/22 13:15	1	S4PD

## Client Sample ID: PBCU5 KITCHEN SINK LEFT

Lab Sample ID: 630-30668-5

Date Collected: 04/07/22 06:38

Matrix: Drinking Water

Date Received: 04/07/22 14:27

PWSID Number: NJ2110300

### Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Copper	0.24		0.010	0.0023	mg/L		04/18/22 13:26	1	S4PD
Lead	0.017		0.0010	0.00069	mg/L		04/18/22 13:26	1	S4PD

## Client Sample ID: PBCU6 NURSES HAND SINK

Lab Sample ID: 630-30668-6

Date Collected: 04/07/22 06:30

Matrix: Drinking Water

Date Received: 04/07/22 14:27

PWSID Number: NJ2110300

### Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Copper	0.21		0.010	0.0023	mg/L		04/18/22 13:07	1	S4PD
Lead	ND		0.0010	0.00069	mg/L		04/18/22 13:07	1	S4PD

## Client Sample Results

Client: Harmony Township Board of Education  
Project/Site: Harmony Township Elementary - Lead/Copper

Job ID: 630-30668-1

### Client Sample ID: PBCU7 FTN BY ROOM 105

Date Collected: 04/07/22 06:33

Date Received: 04/07/22 14:27

Lab Sample ID: 630-30668-7

Matrix: Drinking Water

PWSID Number: NJ2110300

#### Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Copper	0.25		0.010	0.0023	mg/L		04/18/22 12:21	1	S4PD
Lead	0.0016		0.0010	0.00069	mg/L		04/18/22 12:21	1	S4PD

### Client Sample ID: PBCU8 TEACHERS LOUNGE

Date Collected: 04/07/22 06:27

Date Received: 04/07/22 14:27

Lab Sample ID: 630-30668-8

Matrix: Drinking Water

PWSID Number: NJ2110300

#### Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Copper	0.22		0.010	0.0023	mg/L		04/18/22 13:14	1	S4PD
Lead	0.00084	J	0.0010	0.00069	mg/L		04/18/22 13:14	1	S4PD

### Client Sample ID: PBCU9 LEFT FTN BY STORAGE

Date Collected: 04/07/22 06:37

Date Received: 04/07/22 14:27

Lab Sample ID: 630-30668-9

Matrix: Drinking Water

PWSID Number: NJ2110300

#### Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Copper	0.047		0.010	0.0023	mg/L		04/18/22 12:01	1	S4PD
Lead	ND		0.0010	0.00069	mg/L		04/18/22 12:01	1	S4PD

### Client Sample ID: PBCU10 KINDERGARTEN HS

Date Collected: 04/07/22 06:31

Date Received: 04/07/22 14:27

Lab Sample ID: 630-30668-10

Matrix: Drinking Water

PWSID Number: NJ2110300

#### Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Copper	0.14		0.010	0.0023	mg/L		04/18/22 12:23	1	S4PD
Lead	0.0020		0.0010	0.00069	mg/L		04/18/22 12:23	1	S4PD

## Action Limit Summary

Client: Harmony Township Board of Education  
Project/Site: Harmony Township Elementary - Lead/Copper

Job ID: 630-30668-1

**Client Sample ID: PBCU1 KITCHEN SINK RIGHT**

**Lab Sample ID: 630-30668-1**

**PWSID Number: NJ2110300**

### Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL	RL	Method	Prep Type
				Limit			
Copper	0.15		mg/L	1	0.010	200.8	Total/NA
Lead	0.0022		mg/L	0.02	0.0010	200.8	Total/NA

**Client Sample ID: PBCU2 2ND FL FTN CORRIDOR**

**Lab Sample ID: 630-30668-2**

**PWSID Number: NJ2110300**

### Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL	RL	Method	Prep Type
				Limit			
Copper	0.071		mg/L	1	0.010	200.8	Total/NA
Lead	ND		mg/L	0.02	0.0010	200.8	Total/NA

**Client Sample ID: PBCU3 RIGHT FTN BY STORAGE**

**Lab Sample ID: 630-30668-3**

**PWSID Number: NJ2110300**

### Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL	RL	Method	Prep Type
				Limit			
Copper	0.045		mg/L	1	0.010	200.8	Total/NA
Lead	ND		mg/L	0.02	0.0010	200.8	Total/NA

**Client Sample ID: PBCU4 RIGHT FTN BY BOYS RM**

**Lab Sample ID: 630-30668-4**

**PWSID Number: NJ2110300**

### Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL	RL	Method	Prep Type
				Limit			
Copper	0.046		mg/L	1	0.010	200.8	Total/NA
Lead	ND		mg/L	0.02	0.0010	200.8	Total/NA

**Client Sample ID: PBCU5 KITCHEN SINK LEFT**

**Lab Sample ID: 630-30668-5**

**PWSID Number: NJ2110300**

### Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL	RL	Method	Prep Type
				Limit			
Copper	0.24		mg/L	1	0.010	200.8	Total/NA
Lead	0.017		mg/L	0.02	0.0010	200.8	Total/NA

## Action Limit Summary

Client: Harmony Township Board of Education  
Project/Site: Harmony Township Elementary - Lead/Copper

Job ID: 630-30668-1

**Client Sample ID: PBCU6 NURSES HAND SINK**

**Lab Sample ID: 630-30668-6**

**PWSID Number: NJ2110300**

### Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL	RL	Method	Prep Type
				Limit			
Copper	0.21		mg/L	1	0.010	200.8	Total/NA
Lead	ND		mg/L	0.02	0.0010	200.8	Total/NA

**Client Sample ID: PBCU7 FTN BY ROOM 105**

**Lab Sample ID: 630-30668-7**

**PWSID Number: NJ2110300**

### Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL	RL	Method	Prep Type
				Limit			
Copper	0.25		mg/L	1	0.010	200.8	Total/NA
Lead	0.0016		mg/L	0.02	0.0010	200.8	Total/NA

**Client Sample ID: PBCU8 TEACHERS LOUNGE**

**Lab Sample ID: 630-30668-8**

**PWSID Number: NJ2110300**

### Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL	RL	Method	Prep Type
				Limit			
Copper	0.22		mg/L	1	0.010	200.8	Total/NA
Lead	0.00084	J	mg/L	0.02	0.0010	200.8	Total/NA

**Client Sample ID: PBCU9 LEFT FTN BY STORAGE**

**Lab Sample ID: 630-30668-9**

**PWSID Number: NJ2110300**

### Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL	RL	Method	Prep Type
				Limit			
Copper	0.047		mg/L	1	0.010	200.8	Total/NA
Lead	ND		mg/L	0.02	0.0010	200.8	Total/NA

**Client Sample ID: PBCU10 KINDERGARTEN HS**

**Lab Sample ID: 630-30668-10**

**PWSID Number: NJ2110300**

### Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL	RL	Method	Prep Type
				Limit			
Copper	0.14		mg/L	1	0.010	200.8	Total/NA
Lead	0.0020		mg/L	0.02	0.0010	200.8	Total/NA



# Accreditation/Certification and Definitions Summary

Client: Harmony Township Board of Education  
Project/Site: Harmony Township Elementary - Lead/Copper

Job ID: 630-30668-1

## Laboratory: Eurofins Lancaster Laboratories Environment Testing, LLC

The accreditations/certifications listed below are applicable to this report.

Authority	Program	Identification Number	Expiration Date
New Jersey	NELAP	PA011	06-30-22

## Qualifiers

### Metals

Qualifier	Qualifier Description
J	Result is less than the RL but greater than or equal to the MDL and the concentration is an approximate value.

## Glossary

Abbreviation	These commonly used abbreviations may or may not be present in this report.
□	Listed under the "D" column to designate that the result is reported on a dry weight basis
%R	Percent Recovery
1C	Result is from the primary column on a dual-column method.
2C	Result is from the confirmation column on a dual-column method.
CFL	Contains Free Liquid
CFU	Colony Forming Unit
CNF	Contains No Free Liquid
DER	Duplicate Error Ratio (normalized absolute difference)
Dil Fac	Dilution Factor
DL	Detection Limit (DoD/DOE)
DL, RA, RE, IN	Indicates a Dilution, Re-analysis, Re-extraction, or additional Initial metals/anion analysis of the sample
DLC	Decision Level Concentration (Radiochemistry)
EDL	Estimated Detection Limit (Dioxin)
LOD	Limit of Detection (DoD/DOE)
LOQ	Limit of Quantitation (DoD/DOE)
MCL	EPA recommended "Maximum Contaminant Level"
MDA	Minimum Detectable Activity (Radiochemistry)
MDC	Minimum Detectable Concentration (Radiochemistry)
MDL	Method Detection Limit
ML	Minimum Level (Dioxin)
MPN	Most Probable Number
MQL	Method Quantitation Limit
NC	Not Calculated
ND	Not Detected at the reporting limit (or MDL or EDL if shown)
NEG	Negative / Absent
POS	Positive / Present
PQL	Practical Quantitation Limit
PRES	Presumptive
QC	Quality Control
RER	Relative Error Ratio (Radiochemistry)
RL	Reporting Limit or Requested Limit (Radiochemistry)
RPD	Relative Percent Difference, a measure of the relative difference between two points
TEF	Toxicity Equivalent Factor (Dioxin)
TEQ	Toxicity Equivalent Quotient (Dioxin)
TNTC	Too Numerous To Count

## Method Summary

Client: Harmony Township Board of Education

Job ID: 630-30668-1

Project/Site: Harmony Township Elementary - Lead/Copper

Method	Method Description	Protocol	Laboratory
200.8	Metals (ICP/MS)	EPA	ELLE
Non-Digest Prep	Preparation, Non-Digested Aqueous Metals	EPA	ELLE

**Protocol References:**

EPA = US Environmental Protection Agency

**Laboratory References:**

ELLE = Eurofins Lancaster Laboratories Environment Testing, LLC, 2425 New Holland Pike, Lancaster, PA 17601, TEL (717)656-2300



Environment Testing  
America

# CHAIN OF CUSTODY

Page \_\_\_\_ of \_\_\_\_



630-30668 Chain of Custody

Loc: 630

30668

MATRIX CODES

213 Witmer Road  
Horsham, PA 19044

Phone: 215-355-3900

Client/Acct. No. HARMONY TWP School  
Address 2551 BELVIDERE RD.

City/State/Zip PHILLIPSBURG, NJ 08865

Phone/Fax 8859-1001 / 859-2277

Client Contact: tim mckeever

Bill to/Report to (if different)

Sampling Site Address (if different) Include State

P.O. No.

PWSID #:

Quote #

e-mail:

# \_\_\_\_ Ascorbic/HCL Vials # \_\_\_\_ HCL Vials

# \_\_\_\_ Na<sub>2</sub>S<sub>2</sub>O<sub>3</sub> \_\_\_\_

# \_\_\_\_ Na OH/Zn acetate pH \_\_\_\_

# \_\_\_\_ HNO<sub>3</sub> pH \_\_\_\_

# \_\_\_\_ H<sub>2</sub>SO<sub>4</sub> pH \_\_\_\_

# \_\_\_\_ NaOH pH \_\_\_\_

# \_\_\_\_ Unpreserved

# \_\_\_\_ HCL # \_\_\_\_ NH<sub>4</sub>Cl # \_\_\_\_ MeOH

# \_\_\_\_ DI Water

ANALYSIS REQUESTED

DW: DRINKING WATER

GW: GROUND WATER

WW: WASTEWATER

SO: SOIL

SL: SLUDGE

OIL: OIL

SOL: NON SOIL SOLID

MI: MISCELLANEOUS

X: OTHER

Field pH, Temp (°C),  
DO, Cl<sub>2</sub>, Cond. etc.

LAB USE ONLY

PROJECT	Collection		G R A B	C O M P	Matrix Code	Number of Containers											# ____ DI Water	Field pH, Temp (°C), DO, Cl2, Cond. etc.																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																									
	Date	Military Time				Total	H 2 S O 4	H C l	V i a l s	H N O 3	N a O H	Z n A c	U N P R E	B A C T																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																													
FIELD ID																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																											

SAMPLED BY: (Name/Company)

TAT: ☐ STANDARD (10 DAY)

Report Format: ☐ Standard ☐ NJ-RDD ☐ SRP-RDD

Field Parameters Analyzed By:

tim mckeever / HARMONY BOE

or DUE DATE \_\_\_\_ / \_\_\_\_ / \_\_\_\_

☐ Standard + QC ☐ Forms ☐ EDD

Initials

Date/Time:

Please call for pricing and availability for rush (<10 day) turnaround and for all but standard reporting format.

SAMPLE		DY EXCHANGES		T E		TED BELOW		US		FULL LEGAL SIGNATURE, DATE AND MILITARY TIME (24 HOUR CLOCK, I.E. 8AM IS 0800, 4 PM IS 1600)	
RELINQUISHED BY SAMPLER		DATE	TIME	RECEIVED BY		DATE	TIME	DELIVERY: <input type="checkbox"/> EQC COURIER <input type="checkbox"/> CLIENT <input type="checkbox"/> UPS <input type="checkbox"/> FEDEX <input checked="" type="checkbox"/> OTHER		Custody Seal Number	
1. <u>Tim McKen</u>		<u>4/7/22</u>	<u>10:09</u>	<u>[Signature]</u>		<u>04/07/22</u>	<u>10:09</u>				
RELINQUISHED BY		DATE	TIME	RECEIVED BY		DATE	TIME	Rec'd Temp.: <u>12.7/19.8</u> Initials: <u>CP1</u> Ice <u>Y</u> Location: <u>WG</u> COMMENTS:			
2. <u>[Signature]</u>		<u>04/07/22</u>	<u>1427</u>	2. <u>PB/Cu Box</u>		<u>04/07/22</u>	<u>1427</u>				
RELINQUISHED BY		DATE	TIME	RECEIVED BY		DATE	TIME				
3.				3.							
RELINQUISHED BY		DATE	TIME	RECEIVED BY		DATE	TIME				
4.				4.							
RELINQUISHED BY		DATE	TIME	RECEIVED BY		DATE	TIME				
5.				5.							

Page 11 of 14

4/18/2022

## Eurofins Environment Testing Philadelphia-

213 Witmer Road

Horsham, PA 19044-0962

Phone: 215-355-3900 Fax: 888-785-8567

## Chain of Custody Record

Environment Testing  
America

<b>Client Information (Sub Contract Lab)</b>		Sampler:		Lab PM Dougherty, Erin		Carrier Tracking No(s):		COC No: 630-7452.1			
Client Contact: Shipping/Receiving		Phone:		E-Mail: Erin.Dougherty@et.eurofinsus.com		State of Origin: New Jersey		Page: Page 1 of 2			
Company: Eurofins Lancaster Laboratories Env, LLC				Accreditations Required (See note) NELAP - New Jersey				Job #: 630-30668-1			
Address: 2425 New Holland Pike,		Due Date Requested: 4/20/2022		Analysis Requested						Preservation Codes: A - HCL M - Hexane B - NaOH N - None C - Zn Acetate O - AsNaO2 D - Nitric Acid P - Na2O4S E - NaHSO4 Q - Na2SO3 F - MeOH R - Na2S2O3 G - Amchlor S - H2SO4 H - Ascorbic Acid T - TSP Dodecahydrate I - Ice U - Acetone J - DI Water V - MCAA K - EDTA W - pH 4-5 L - EDA Z - other (specify)  Other:	
City: Lancaster		TAT Requested (days):									
State, Zip: PA, 17601		PO #:		Field Filled Sample (Yes or No) Perform MS/MSD (Yes or No) 200.8, SDWA/MTL, ND, Prep Cu & Pb only		Total Number of Containers					
Phone: 717-656-2300(Tel)		WO #:									
Email:		Project #: 63002445									
Project Name: Harmony Township Elementary School		SSOW#:									
Site: HARMONY TOWNSHIP BOARD OF EDUCATION											
Sample Identification - Client ID (Lab ID)		Sample Date		Sample Time		Sample Type (C=Comp, G=grab)		Matrix (W=water, S=solid, O=waste/oil, BT=Tissue, A=Air)			
						Preservation Code:					
PBCU1 KITCHEN SINK RIGHT (630-30668-1)		4/7/22		06:39 Eastern		Drinking Water		X			
PBCU2 2ND FL FTN CORRIDOR (630-30668-2)		4/7/22		06:45 Eastern		Drinking Water		X			
PBCU3 RIGHT FTN BY STORAGE (630-30668-3)		4/7/22		06:36 Eastern		Drinking Water		X			
PBCU4 RIGHT FTN BY BOYS RM (630-30668-4)		4/7/22		06:25 Eastern		Drinking Water		X			
PBCU5 KITCHEN SINK LEFT (630-30668-5)		4/7/22		06:38 Eastern		Drinking Water		X			
PBCU6 NURSES HAND SINK (630-30668-6)		4/7/22		06:30 Eastern		Drinking Water		X			
PBCU7 FTN BY ROOM 105 (630-30668-7)		4/7/22		06:33 Eastern		Drinking Water		X			
PBCU8 TEACHERS LOUNGE (630-30668-8)		4/7/22		06:27 Eastern		Drinking Water		X			
PBCU9 LEFT FTN BY STORAGE (630-30668-9)		4/7/22		06:37 Eastern		Drinking Water		X			
Note: Since laboratory accreditations are subject to change, Eurofins Environment Testing Philadelphia, LLC places the ownership of method, analyte & accreditation compliance upon out subcontract laboratories. This sample shipment is forwarded under chain-of-custody. If the laboratory does not currently maintain accreditation in the State of Origin listed above for analysis/tests/matrix being analyzed, the samples must be shipped back to the Eurofins Environment Testing Philadelphia, LLC laboratory or other instructions will be provided. Any changes to accreditation status should be brought to Eurofins Environment Testing Philadelphia, LLC attention immediately. If all requested accreditations are current to date, return the signed Chain of Custody attesting to said compliance to Eurofins Environment Testing Philadelphia, LLC.											
<b>Possible Hazard Identification</b>						<b>Sample Disposal (A fee may be assessed if samples are retained longer than 1 month)</b>					
Unconfirmed						<input type="checkbox"/> Return To Client <input type="checkbox"/> Disposal By Lab <input type="checkbox"/> Archive For _____ Months					
Deliverable Requested: I, II, III, IV, Other (specify)						Primary Deliverable Rank: 1					
Special Instructions/QC Requirements:											
Empty Kit Relinquished by:				Date:		Time:		Method of Shipment:			
Relinquished by:				Date/Time: 04/07/22 1427		Company: EETP		Received by:			
Relinquished by:				Date/Time:		Company:		Received by:			
Relinquished by:				Date/Time:		Company:		Received by:			
Custody Seals Intact: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No				Custody Seal No.: Ackerman		Cooler Temperature(s) °C and Other Remarks: 0.80°C					



**eurofins** Environment Testing America

Page 13 of 14

[illegible]Page 14 of 14